



EDGE OF CONCRETE APRON (SEE NOTES 1 & 2)

SUPPLY AUTHORITIES MAINS ENTRY. DIRECTED TO POINT OF SUPPLY.

NOTES:

1. IN UNSEALED AREAS. A COURTESY APRON SHALL BE PROVIDED. CONSISTING OF 80MM THICK CONCRETE. EXTENDED 200MM AROUND THE FOOTING. EXCEPT IN FRONT OF THE DOOR WHERE THE APRON SHALL BE 600MM WIDE.
2. CONCRETE STRENGTH GRADE SHALL BE N32 TO THE REQUIREMENTS OF AS-1579 "SPECIFICATION OF CONCRETE".
3. THREADED PORTION OF RAG BOLTS TO BE COATED WITH GRAPHITE GREASE OR SIMILAR AND PROTECTED FROM DAMAGE DURING ASSEMBLY.
4. 20MM SHALL PROTRUDE 50MM ABOVE THE CONCRETE FOOTINGS.
5. A CLEARANCE OF 1000MM MUST BE MAINTAINED IN FRONT OF THE CABINET.
6. FOUNDATION TO BE MINIMUM CLEARANCE OF 500MM TO BACK OF KERB AND 200MM FORM THE BUILDING LINES, POLES ETC.
7. REFERENCE STANDARD DRAWING SD 101 024 FOR RAG BOLT ASSEMBLY FOR CABINET

CONDUIT SPECIFICATION (TO AS 2053)

E100 = ELECTRICAL (ORANGE) HEAVY DUTY CONDUIT 100 DIA

E50 = ELECTRICAL (ORANGE) HEAVY DUTY CONDUIT 50 DIA

E20 = ELECTRICAL (ORANGE) HEAVY DUTY CONDUIT 20 DIA

DEPARTMENT OF STATE GROWTH

STANDARD DRAWING
 CONTROLLER FOUNDATION DETAILS
 DRAWING ADAPTED FROM VICROADS STANDARD DRAWING TC-1203

ISSUE	DETAILS	DRN	DATE
A	UPDATES TO STANDARD VIC ROADS DRAWINGS		
B	UPDATE TO STANDARD DRAWING	B.V	18/02/2021
C	C20 COMMUNICATION CONDUIT REMOVED	B.V	14/07/2022

DRAWN	B. VINEY
REVIEWED	N. HARREX
APPROVED	



DO NOT SCALE

USE OF THIS DRAWING IS GOVERNED BY THE CONDITIONS ON THE DEPARTMENT STATE GROWTH WEBSITE. IT IS THE USERS RESPONSIBILITY TO ENSURE IT IS THE CURRENT REVISION. STANDARD DRAWING NUMBER	SD-101-019
REVISION NUMBER	C